

Annual Report of Activities: October 1, 2012 to September 30, 2013

American River Group (ARG), September 2013

Correction to Table 2:

7/2/2013	Raise the Top set of temperature shutters on Folsom Penstock Unit 2. Change due to water elevation requirement to prevent structural failure/cavitation.
7/3/2013	Raise the Top set of temperature shutters on Folsom Penstock Unit 3. Change due to water elevation requirement to prevent structural failure/cavitation.
7/25/2013	Raise the Middle set of temperature shutters on Folsom Penstock Unit 3.